



- NOTES:**
1. REMOVE ALL BURRS AND SHARP EDGES
 2. ONE OF THE BAFFLES MUST BE CENTERED BETWEEN DIP TUBES
 3. TANK IS DESIGNED TO SUPPORT GENSET
 4. **TANK TO BE PRESSURE TESTED TO 3 PSI**
 5. TANK TO BE INSTALLED IN ACCORDANCE WITH AFFIXED LABELING, THE FLAMMABLE AND COMBUSTIBLE LIQUID CODES, NFPA 30 AND ANY OTHER PREVAILING CODES
 6. TANK IS DESIGNED AS SECONDARY CONTAINMENT, SINGLE TOP
 7. UNLESS OTHERWISE SPECIFIED; WELD FLANGE FITTINGS TO BE USED
 8. UNLESS OTHERWISE SPECIFIED; TANK TO BE FULLY WELDED
 9. VENDOR TO SUPPLY THE FITTINGS WITH REMOVABLE PLUGS
 10. MATERIAL: 10 GA HRPO, UNLESS OTHERWISE SPECIFIED
 11. ***ACCESS PANEL TO BE FASTENED WITH 1/4-20 X 5/8 BOLTS***
 12. **TANK TO BE UL-C AND UL 142 LISTED**
 13. FINISH: GLOSS BLACK
 14. LIFT BRACKETS TO BE CAPABLE OF LIFTING A TOTAL VERTICAL LOAD OF 10,000# PLUS THE WEIGHT OF THE TANK

Rev.	Desc.	By	Date
03	CHANGED LIFT BRACKETS	01774	08-03-10
02	ADD UL-C NOTE	01461	04-08-10
01	REVISED NOTES	01362	03-05-10

Beschreibung / Part Description Oberflächen- Surface Finish Material / Material Gewicht / Weight Referenz / Reference No.	Oberflächen- Surface Specification per: MTR5033 Oberflächen- Surface Specification per: MTR5033 Material / Material Gewicht / Weight Referenz / Reference No.	Maßstab / Scale 0.125 Zeichnung / Drawing No. 1018.462 Blatt / Sheet D
Bei Fremdlieferanten durch alle technischen Änderungen an Lieferungen nur nach unserer vorherigen Genehmigung vorzunehmen. Technical modifications to third party or purchased parts require our prior permission.		Hersteller / Manufacturer onebe energy 90564 Zeichnung / Drawing No. TANK SB 240GL DW UL 100X48X24 24HR Blatt / Sheet 03 / 1/1

Für diese technische Unterlagen behalten wir uns alle Rechte vor. Sie darf ohne unsere Zustimmung weder vervielfältigt, noch Dritten zugänglich gemacht, noch in anderer Weise missbrauchlich verwendet werden. All rights reserved. This document may not be reproduced or disclosed to a third party or used for any other purpose without our express consent.