



- NOTES:
- REMOVE ALL BURRS AND SHARP EDGES
 - ONE OF THE BAFFLES MUST BE CENTERED BETWEEN DIP TUBES
 - TANK IS DESIGNED TO SUPPORT GENSET
 - TANK TO BE PRESSURE TESTED TO 3 PSI**
 - TANK TO BE INSTALLED IN ACCORDANCE WITH AFFIXED LABELING, THE FLAMMABLE AND COMBUSTIBLE LIQUID CODES, NFPA 30 AND ANY OTHER PREVAILING CODES
 - TANK IS DESIGNED AS SECONDARY CONTAINMENT, SINGLE TOP
 - UNLESS OTHERWISE SPECIFIED; WELD FLANGE FITTINGS TO BE USED
 - UNLESS OTHERWISE SPECIFIED; TANK TO BE FULLY WELDED
 - VENDOR TO SUPPLY THE FITTINGS WITH REMOVABLE PLUGS
 - MATERIAL: 3.5 (1.135; 10 GA.) STEEL, ASTM A36 1011, UNLESS OTHERWISE SPECIFIED.
 - ACCESS PANEL TO BE FASTENED WITH 1/4-20 X 5/8 BOLTS**
 - TANK TO BE UL AND UL 142 LISTED**
 - FINISH: GLOSS BLACK
 - LIFT BRACKETS TO BE CAPABLE OF LIFTING A TOTAL VERTICAL LOAD OF 12,500# PLUS THE WEIGHT OF THE TANK

Änderungs-Nr.	Änderungs-Gr.	Datum	Ben.	Gepr.	Check
01	CHANGED LIFT EYES	01774	08-04-10	MTH	

Auftrags-Nr. Zeichnungs-Nr. Projekt-Nr. Kunden-Nr. Zeichnungs-Nr.	Überflächeneigenschaften nach WTS 5033 Oberflächen siehe WTS 5033 Material siehe WTS 5033 Projekt-Nr. WTS 5033 Zeichnungs-Nr. WTS 5033	Revision 0.125 Stückzahl 1362.346 D
SEE NOTES		
TANK SB 370GL DW UL 112X48X34 24HR		
92486		Revision 01 Blatt 1/1